#### SAFETY ORGANIZATIONS

THIS FILTER HAS BEEN FORMALLY RECOGNIZED, CERTIFIED OR APPROVED BY THE LISTED AGENCY. THEREFORE, ALL TEST/REQUIREMENTS SPECIFIED IN THE LATEST REVISION OF THE FOLLOWING AGENCY STANDARDS HAVE BEEN MET:

UL RECOGNIZED: UL 1283 cUR PER CSA C22.2 No. 8

## OPERATING SPECIFICATIONS

LINE CURRENT/VOLTAGE: 20 AMP/40°C, 300 VAC 50-60Hz (UR) PENDING AMP/40°C, 250 VAC 50-60Hz (cUR) PENDING

MAXIMUM LEAKAGE CURRENT,

EACH LINE TO GROUND:

0.12mA @ 120 VAC 60Hz 0.25mA @ 250 VAC 60Hz

@ 300 VAC 60Hz 0.30mA

OPERATING AMBIENT TEMP. RANGE: ~10°C TO +40°C @ RATED CURRENT, Ir.

IN AN AMBIENT,  $T_0$ , HIGHER THAN 40°C, THE MAXIMUM OPERATING CURRENT,  $I_0$ , IS AS FOLLOWS:  $I_0 = I_0 - \sqrt{100 - T_0}$ 

100 - Ta  $I_0 = I_r -$ 60

## RELIABILITY SPECIFICATIONS:

STORAGE TEMPERATURE: -40°C TO +100°C HUMIDITY: 21 DAYS € 40°C 95% RH. CURRENT OVERLOAD TEST: 6 TIMES In FOR

8 SECONOS

#### TEST SPECIFICATIONS:

INDUCTANCE: 0.44 mH NOMINAL CAPACITANCE: (MEASURED @ IKHz, 0.250VAC MAX., 25°C±1°C1

LINE TO GROUND: LINE TO LINE: 0.0040 μF±20% 0.010 μF±20%

DISCHARGE RESISTOR: 1.5 MA

L/G AND L/L I.R.

NO DISCHARGE RESISTOR: 6000M₁ (MIN.) @ 100VDC,

20°C AND 50% RH

CUSTOMER DRAWING

20FBL3

APPRVO L DATE

CATALOG #

ECN#

## RECOMMENDED RECEIVING INSPECTION HIPOT:

LINE TO GROUND: 2263 VDC FOR I MINUTE LINE TO LINE: 2263 VDC FOR I MINUTE

# FILTER APPROVAL:

THE BEST WAY TO SELECT AND QUALIFY A FILTER IS FOR YOUR ENGINEERING TO TEST THE UNIT IN YOUR EQUIPMENT.

