

DESCRIPTION APPROVED BY DATE REV C. Westuby 11-30-90 0 10DEC09 ECO-09-026495 **AEG**

SAFETY ORGANIZATION(S):

THIS FILTER HAS BEEN FORMALLY RECOGNIZED. CERTIFIED OR APPROVED BY THE LISTED AGENCY. THEREFORE, ALL TEST/REQUIREMENTS SPECIFIED IN THE LATEST REVISION OF THE FOLLOWING AGENCY STANDARDS HAVE BEEN MET:

UL 1283

UL RECOGNIZED

CSA CERTIFIED (PENDING) CSA 22.2, NO.0, 0.4, 8

VDE APPROVED (PENDING) VDE 565-3

OPERATING SPECIFICATIONS:

LINE VOLTAGE/CURRENT: 20 AMP., 120/250 VAC 16 AMP./40°C, 250 VAC

LINE FREQUENCY: 50-60Hz

MAX. LEAKAGE CURRENT. EACH

.50 mA @ 120V 60 Hz LINE TO GROUND .83 mA @ 250V 50 Hz

OPERATING AMBIENT TEMP. RANGE:

-10°C TO +40°C @ RATED CURRENT, In

IN AN AMBIENT, Ta, HIGHER THAN 40°C, THE MAXIMUM OPERATING

CURRENT, I, IS AS FOLLOWS:

RELIABILITY SPECIFICATIONS:

STORAGE TEMPERATURE: -40°C TO +85°C

HUMIDITY: 21 DAYS @ 40°C 95% RH

CURRENT OVERLOAD TEST: 6 TIMES RATED CURRENT FOR 8 SECONDS

TEST SPECIFICATIONS:

INDUCTANCE: .54 mH NOMINAL

CAPACITANCE: (MEASURED @ 1 KHz, 0.25 VAC MAX., 25°C ±1°C)

.0055μF ±20% LINE TO GROUND: 1.08µF ±20% LINE TO LINE:

DISCHARGE RESISTOR 330Kn

LINE/GROUND AND LINE/LINE 6000 MΩ (MIN) AT 100 VDC

20°C AND 50% RH INSULATION RESISTANCE

RECOMMENDED RECEIVING INSPECTION HIPOT:

LINES TO GROUND: 2250 VDC FOR 1 MINUTE LINE TO LINE: 1450 VDC FOR 1 MINUTE

FILTER APPROVAL:

THE BEST WAY TO SELECT AND QUALIFY A FILTER IS FOR YOUR ENGINEERING TO TEST THE UNIT IN YOUR EQUIPMENT.

LINE		LOAD
------	--	------

PER D.RENAUD/D.SINISI

													10 1201 THE ONLY IN 10011
	50	7 -	50Ω	(MI	NIMU	CMI	INSE	RTIC	ON L	055			TOLERANCE EXCEPT AS NO
FREQUENCY MHz	. 15	.5	1	2	5	10	20	30					DECIMAL: .XXX .XX .X A ENGLISH: ±.025
COMMON dB	10	23	30	34	39	44	49	55					METRIC: ± —— MATERIAL:
DIFF. dB	20	43	55	62	65	60	55	55					AS SUPPLIED
This docu to be rep except or	prod	uced	nor	use	d fo	r mc	anufo	actur	ring	pur	pose	not s	FINISH: AS SUPPLIED

TED ANGLES ± 1°

LIBERTYVILLE.IL 60048

POWER LINE FILTER

NTS 11-5-90 CFW

20VDK6

1-6609034-0