SAFETY ORGANIZATIONS

THIS FILTER HAS BEEN FORMALLY RECOGNIZED, CERTIFIED OR APPROVED BY THE LISTED AGENCY. THEREFORE, ALL TEST/REQUIREMENTS SPECIFIED IN THE LATEST REVISION OF THE FOLLOWING AGENCY STANDARDS HAVE BEEN MET:

UL RECOGNIZED: UL 60939-3

OPERATING SPECIFICATIONS

LINE CURRENT/VOLTAGE: 5.0 AMP/90°C, 480 VAC 50-60Hz 5.0 AMP/90°C, 480 VDC

MAXIMUM LEAKAGE CURRENT,

EACH LINE TO GROUND: 0.28 mA @ 277V 60Hz 0.21 mA @ 250V 50Hz

OPERATING AMBIENT TEMP. RANGE: -40°C TO +90°C @ RATED CURRENT, In. IN AN AMBIENT, T_0 , HIGHER THAN 90°C, THE MAXIMUM OPERATING CURRENT, I_0 , IS AS FOLLOWS: $T_1 = T_1 - T_2 = T_3 - T_4 = T$

100 - Ta $I_0 = I_r -$ 10

RELIABILITY SPECIFICATIONS:

STORAGE TEMPERATURE: -40°C TO +100°C HUMIDITY: 21 DAYS € 40°C 95% RH. CURRENT OVERLOAD TEST: 6 TIMES Ir FOR 8 SECONDS

CUSTOMER DRAWING CATALOG # 5FBH3 APPRVD ECN#

TEST SPECIFICATIONS:

INDUCTANCE: 0.51 mH NOMINAL

 $0.51~\mathrm{mH}$ NOMINAL

CAPACITANCE: (MEASURED @ 1 kHz, 0.250VAC MAX., 25°C±1°C)

LINE TO GROUND: 0.0044uF ± 20 % LINE TO LINE: 0.011uF ± 20 % DISCHARGE RESISTOR: 20 MEGOHM

I/G AND I/I I.R.

NO DISCHARGE RESISTOR: 6000MEGOHM (MIN.) 100VDC 20°C AND 50% RH

RECOMMENDED RECEIVING INSPECTION HIPOT:

2250 VDC FOR 1 MINUTE LINE TO LINE: 2775 VDC FOR 1 MINUTE

FILTER APPROVAL:

THE BEST WAY TO SELECT AND QUALIFY A FILTER IS FOR YOUR ENGINEERING TO TEST THE UNIT IN YOUR EQUIPMENT.



